



## TEST HOLE INVENTORY REPORT

### Route 623 Infrastructure Improvements

<u>Date</u>	<u>TH#</u>	<u>Utility Requested</u>	<u>Utility Found</u>	<u>Existing Grade Depth</u>	<u>Material Type</u>	<u>Utility Elevation</u>	<u>Pavement Thickness</u>	<u>Utility Owner</u>
04/16/09	1	Water	6" Water	3.13'	PVC	159.21'	0.7' Asph	N/A
04/16/09	2	Gas	6" Gas	3.72'	PE	158.04'	N/A	N/A
04/16/09	3	6" Water	6" Water	4.02'	PVC	158.23'	N/A	N/A
04/16/09	3A	6" Water	6" Water	4.73'	DI	160.61'	N/A	N/A
04/16/09	3B	Water	6" Water	3.66'	PVC	158.11'	0.4' Conc	N/A
04/21/09	4	Gas	4" Gas	2.53'	PE	158.95'	0.4' Conc	N/A
04/16/09	5	Water	6" Water	2.98'	PVC	158.44'	N/A	N/A
04/17/09	6	4" Water	2" Water / 12" Unknown	3.05' / 3.28'	Steel / Cast Iron	159.01'	0.4' Conc	N/A
04/17/09	7	4" Water	See Note	See Note	See Note	N/A	N/A	N/A
04/15/09	8	Telephone	Telephone Duct Bank	4.12' / 6.03'	Conc.	158.75'	0.7' Asph	N/A

Smith Engineering - Point of Contact: John Smith (555) 555-1212

AccuMark - Point of Contact: Dan Parker (555) 555-1212 cell